


# **FLOW PERFORMANCE TESTING OF 4-INCH, AND 8-INCH STRAINERS**

**Prepared for**

**Metraflex**

**February 2017**



**UTAH WATER RESEARCH LABORATORY**

**Utah State University  
Logan, Utah**

**Report No. 3732**

# FLOW PERFORMANCE TESTING OF 4-INCH AND 8-INCH STRAINERS

Prepared for:

Metraflex  
2323 W. Hubbard St.  
Chicago, IL 60612

Prepared by:

Michael C. Johnson, PhD, PE

Utah State University  
Utah Water Research Laboratory  
Logan, UT 84322-8200

February 2017

Hydraulics Report No. 3732

## INTRODUCTION

Flow performance tests were conducted at the Utah Water Research Laboratory (UWRL) on 4-inch, and 8-inch Mueller Steam basket strainers. The testing was developed to determine the flow versus pressure loss characteristics for each strainer and the flow coefficient of each strainer. Strainers 4-inch and larger strainers each had 0.125 inch perforations. The work was authorized under Metraflex Purchase Order No. 32338 and was done in accordance with the ANSI/ISA 75.02.01-2008 Control Valve Capacity Test Procedures standard with slight modifications in order to characterize each strainer's performance over a wide flow range.

## EXPERIMENTAL PROGRAM

Each of the strainers was installed in a test line (standard steel diameters) with approximately 20 diameters of straight approach piping to provide uniform flow at the inlet of the strainer. There were approximately 10 diameters of straight pipe downstream from the strainer. Pressure taps were located two pipe diameters upstream from the strainer and six pipe diameters downstream from the strainer. Flow was supplied with laboratory pumps. Figures 1 and 2 show the typical test setups for the strainers for the 4-inch and 12-inch strainers. Each of the other sizes had similar installations however they were installed in pipe sizes corresponding to each strainer size.



Figure 1. 4-inch strainer installation (Mueller Steam strainer shown).



Figure 2. 12-inch strainer installation (Metraflex strainer shown).

The flow rate was measured using calibrated flow meters which were verified against certified weight tanks. The differential pressure across the strainer was measured using Rosemount differential transmitters. The upstream pressure was measured using a Rosemount transmitter. The water temperature was measured using a calibrated RTD.

Each strainer was tested over a range of flows sufficient to generate 1.5 ft/s to 15 ft/s average velocities in the approach pipe. Ten points were taken over the velocity range of each size.

To prevent screen plugging during testing, the laboratory used screens upstream of the various installations to capture any debris that entered the test system from water supplied from Logan River.

## **FLOW COEFFICIENT**

The definition of the flow coefficient used in this report is:

$$C_v = \frac{Q}{\sqrt{\frac{\Delta P}{SG}}}$$

Where  $Q$  is the discharge of test fluid in U.S. gallons per minute flowing through the strainer,  $\Delta P$  is the pressure drop across the strainer in psi, and  $SG$  is the specific gravity of the test fluid.  $C_v$  is calculated using the gross pressure drop (ISA standard) between taps that are two diameters upstream and six diameters downstream.

The net flow coefficient was also computed by subtracting the friction expected from steel pipe between the gross differential pressure measured between the pressure taps. This calculation was

completed using the Swamee-Jain equation to determine the friction factor associated with the specific data point taken in the laboratory. The Swamee-Jain equation is given by:

$$f = \frac{1.325}{\left( \ln \left( \frac{k}{3.7D} + \frac{5.74}{Re^{0.9}} \right) \right)^2}$$

Where  $f$  is the friction factor,  $k$  is the pipe roughness,  $D$  is the inside diameter of the pipe and  $Re$  is the Reynolds number of the flow in the pipe. The headloss in feet was then converted to psi and subtracted from the gross pressure loss measurement.

## TEST PROCEDURE

The test procedure essentially followed ISA 75.02.01-2008 with slight modifications to account for the fact that a strainer is not a valve and it was desired to determine the strainer's performance characteristics over a wide flow range.

### *C<sub>v</sub> Determination*

1. Install the strainer in straight piping of nominal size and standard wall thickness. Ensure that at least 20 diameters of straight pipe are upstream from the strainer and at least 8 diameters are installed downstream from the strainer.
2. Flow test the strainer at several different flow rates and observe the relationship between flow and  $C_v$ .
3. The following data shall be recorded:
  - a) Upstream pressure (measurement not to exceed 2 percent of actual value).
  - b) Pressure differential across the strainer (measurement not to exceed 2 percent of actual value).
  - c) Volumetric flow rate (measurement not to exceed 2 percent of actual value).
  - d) Fluid temperature (measurement error not to exceed 2 degrees Fahrenheit).
  - e) Strainer description and identifying numbers.
4. Calculate the gross and net flow coefficient  $C_v$ .

## TEST RESULTS

The pressure loss and flow coefficient  $C_v$  data are given in Tables 1 through 6 and the net pressure loss and net flow coefficient data are shown graphically on Figures 3 through 8.

**Table 2. Strainer Flow Performance Testing**

**4" Metraflex LPD 0.125 Perforations**

Reference Data	
Pipe Dia. (I.D. in.) =	4.026
Inlet Pipe Area (ft <sup>2</sup> ) =	0.088
Pipe roughness (ft) =	0.00015
Pipe Friction Length (ft) =	2.667
Water temp. (F) =	47.4
Unit weight H2O (pcf) =	62.42
Density (slug) =	1.940
Specific Gravity H2O =	1.0008
Vapor pressure (psia) =	0.16
Viscosity (cP) =	1.3632
Kinematic visc. (ft <sup>2</sup> /s) =	1.47E-05

Tested by: E. Fisher 11-2-15  
 SS Prepared by: Michael C. Johnson 8/20/12  
 SS Checked by: Zac Sharp 8/27/12  
 Witnessed by: -



Run No.	Flow Measurement							Differential Measurement								Coef. gross	Coef. net
	Key	Mag. Hz	Weight lbs	Time s	Mag gpm	W. Tank gpm	V (pipe) ft/s	Pu Span psi	Pu V	DP Span psi	DP V	Pu (psi)	Pd (psi)	ΔP gross (psi)	ΔP net (psi)		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
1	6M	237.20			59.30		1.49	35	4.790	4	1.0197	33.16	33.14	0.0197	0.0168	422.7	457.3
2	6M	476.60			119.15		3.00	35	4.754	4	1.0778	32.85	32.77	0.0778	0.0675	427.3	458.7
3	6M	713.90			178.48		4.50	35	4.714	4	1.1748	32.50	32.32	0.1748	0.1531	427.1	456.4
4	6M	948.70			237.18		5.98	35	4.665	4	1.3054	32.07	31.76	0.3054	0.2683	429.3	458.0
5	6M	1195.30			298.83		7.53	35	4.602	4	1.4844	31.52	31.03	0.4844	0.4270	429.5	457.5
6	6M	1431.80			357.95		9.02	35	4.531	4	1.6868	30.90	30.21	0.6868	0.6059	432.1	460.0
7	25K	1675.70	14000	240.48	418.93	418.63	10.56	35	4.506	4	1.9346	30.68	29.74	0.9346	0.8254	433.5	461.3
8	6M	1903.80			475.95		12.00	35	4.485	4	2.1970	30.49	29.30	1.1970	1.0575	435.2	463.0
9	6M	2141.00			535.25		13.49	35	4.454	4	2.5110	30.22	28.71	1.5110	1.3361	435.6	463.2
10	6M	2384.00			596.00		15.02	35	4.398	4	2.8640	29.73	27.87	1.8640	1.6489	436.7	464.3
<b>Average =</b>															<b>430.9</b>	<b>460.0</b>	

**Table 3. Strainer Flow Performance Testing**

**4" Mueller Basket Strainer**  
**Screen perforation: 0.125"**

Reference Data	
Pipe Dia. (I.D. in.) =	4.026
Inlet Pipe Area (ft <sup>2</sup> ) =	0.088
Pipe roughness (ft) =	0.00015
Pipe Friction Length (ft) =	2.667
Water temp. (F) =	41.4
Unit weight H2O (pcf) =	62.43
Density (slug) =	1.940
Specific Gravity H2O =	1.0009
Vapor pressure (psia) =	0.13
Viscosity (cP) =	1.5078
Kinematic visc. (ft <sup>2</sup> /s) =	1.62E-05

Tested by: M. Cannor 11/3/2015  
 SS Prepared by: Michael C. Johnson 8/20/12  
 SS Checked by: Zac Sharp 8/27/12  
 Witnessed by: -



Run No.	Flow Measurement							Differential Measurement								Coef.	Coef.
	Key	Mag. Hz	Weight lbs	Time s	Mag gpm	W. Tank gpm	V (pipe) ft/s	Pu Span psi	Pu V	DP Span psi	DP V	Pu (psi)	Pd (psi)	ΔP gross (psi)	ΔP net (psi)	Cv gross	Cv net
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
1	6M	235.40	1700	205.72	58.85	59.41	1.48	50	3.640	4	1.0355	33.00	32.96	0.0355	0.0326	312.5	326.0
2	6M	480.20			120.05		3.03	50	3.615	4	1.1486	32.69	32.54	0.1486	0.1380	311.6	323.3
3	6M	717.90			179.48		4.52	50	3.581	4	1.3295	32.26	31.93	0.3295	0.3072	312.8	323.9
4	6M	952.70	7000	210.97	238.18	238.56	6.00	50	3.544	4	1.5849	31.80	31.22	0.5849	0.5471	311.6	322.2
5	6M	1202.30			300.58		7.58	50	3.500	4	1.9348	31.25	30.32	0.9348	0.8762	311.0	321.3
6	6M	1438.20			359.55		9.06	50	3.444	4	2.3420	30.55	29.21	1.3420	1.2596	310.5	320.5
7	6M	1677.10	12000	205.63	419.28	419.58	10.57	50	3.412	4	2.8340	30.15	28.32	1.8340	1.7236	309.7	319.5
8	6M	1897.60			474.40		11.96	50	3.395	4	3.3660	29.94	27.57	2.3660	2.2262	308.6	318.1
9	6M	2147.00			536.75		13.53	50	3.377	4	4.0080	29.71	26.70	3.0080	2.8309	309.6	319.2
10	6M	2382.00	17000	205.12	595.50	595.88	15.01	50	3.335	4	4.6790	29.19	25.51	3.6790	3.4627	310.6	320.2
<b>Average =</b>																<b>310.9</b>	<b>321.4</b>

**Table 4. Strainer Flow Performance Testing**

**8" Metraflex LPD 0.125 Perforations**

Reference Data	
Pipe Dia. (I.D. in.) =	7.981
Inlet Pipe Area (ft <sup>2</sup> ) =	0.347
Pipe roughness (ft) =	0.00015
Pipe Friction Length (ft) =	5.333
Water temp. (F) =	47.4
Unit weight H2O (pcf) =	62.42
Density (slug) =	1.940
Specific Gravity H2O =	1.0008
Vapor pressure (psia) =	0.16
Viscosity (cP) =	1.3632
Kinematic visc. (ft <sup>2</sup> /s) =	1.47E-05

Tested by: M. Cannon 11-3-15  
 SS Prepared by: Michael C. Johnson 8/20/12  
 SS Checked by: Zac Sharp 8/27/12  
 Witnessed by: -



Run No.	Flow Measurement							Differential Measurement								Coef.	Coef.
	Key	Mag. Hz	Weight lbs	Time s	Mag gpm	W. Tank gpm	V (pipe) ft/s	Pu Span psi	Pu V	DP Span psi	DP V	Pu (psi)	Pd (psi)	ΔP gross (psi)	ΔP net (psi)	Cv gross	Cv net
1	250K	14.57	4000	194.22	148.29	148.10	0.95	35	4.740	6	1.0064	32.73	32.72	0.0096	0.0085	1514.0	1607.8
2	250K	24.82			250.90		1.61	35	4.690	6	1.0187	32.29	32.26	0.0280	0.0252	1498.6	1580.1
3	250K	40.21			405.28		2.60	35	4.610	6	1.0481	31.59	31.52	0.0722	0.0654	1509.4	1585.9
4	250K	54.02	15100	200.00	543.98	542.92	3.49	35	4.640	6	1.0868	31.85	31.72	0.1302	0.1185	1508.2	1581.0
5	250K	66.67			669.94		4.30	35	4.610	6	1.1321	31.59	31.39	0.1982	0.1809	1505.6	1575.9
6	250K	80.60			808.15		5.18	35	4.550	6	1.1925	31.06	30.77	0.2888	0.2642	1504.5	1573.0
7	250K	93.98	26140	200.00	941.42	939.86	6.04	35	4.490	6	1.2604	30.54	30.15	0.3906	0.3578	1506.9	1574.4
8	250K	108.64			1088.33		6.98	35	4.410	6	1.3487	29.84	29.31	0.5231	0.4799	1505.4	1571.6
9	250K	119.31			1195.01		7.66	35	4.340	6	1.4201	29.23	28.59	0.6302	0.5786	1506.0	1571.6
10	250K	133.71	37180	200.00	1338.99	1336.79	8.59	35	4.250	6	1.5257	28.44	27.65	0.7886	0.7246	1508.5	1573.7
11	250K	171.72			1720.00		11.03	35	3.930	6	1.8597	25.64	24.35	1.2896	1.1863	1515.2	1579.8
12	250K	201.10			2015.00		12.92	35	3.610	6	2.1760	22.84	21.07	1.7640	1.6240	1517.7	1581.8
13	250K	234.90			2352.77		15.09	35	3.190	6	2.6060	19.16	16.75	2.4090	2.2201	1516.5	1579.7
<b>Average =</b>																<b>1506.7</b>	<b>1579.5</b>



**Table 5. Strainer Flow Performance Testing**

**8" Mueller Basket Strainer**  
**Screen perforation: 0.125"**

Reference Data	
Pipe Dia. (I.D. in.) =	7.981
Inlet Pipe Area (ft <sup>2</sup> ) =	0.347
Pipe roughness (ft) =	0.00015
Pipe Friction Length (ft) =	5.333
Water temp. (F) =	41.4
Unit weight H <sub>2</sub> O (pcf) =	62.43
Density (slug) =	1.940
Specific Gravity H <sub>2</sub> O =	1.0009
Vapor pressure (psia) =	0.13
Viscosity (cP) =	1.5078
Kinematic visc. (ft <sup>2</sup> /s) =	1.62E-05

Tested by: M. Cannon 2/17/17  
 SS Prepared by: Michael C. Johnson 8/20/12  
 SS Checked by: Zac Sharp 8/27/12  
 Witnessed by: -



Run No.	Flow Measurement							Differential Measurement								Coef.	Coef.
	Key	Mag. Hz	Weight lbs	Time s	Mag gpm	W. Tank gpm	V (pipe) ft/s	Pu Span psi	Pu V	DP Span psi	DP V	Pu (psi)	Pd (psi)	ΔP gross (psi)	ΔP net (psi)	Cv gross	Cv net
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
1	12M	23.80	7000	208.34	240.54	241.57	1.54	50	3.586	4	1.0480	32.33	32.28	0.0480	0.0453	1098.4	1130.1
2	12M	45.92			460.57		2.95	50	3.539	4	1.1760	31.74	31.56	0.1760	0.1673	1098.4	1126.7
3	12M	69.83			698.36		4.48	50	3.532	4	1.4064	31.65	31.24	0.4064	0.3875	1096.0	1122.4
4	12M	94.31	26200	200.00	941.65	941.87	6.04	50	3.470	4	1.7314	30.88	30.14	0.7314	0.6982	1101.6	1127.4
5	12M	117.30			1170.75		7.51	50	3.393	4	2.1280	29.91	28.78	1.1280	1.0779	1102.8	1128.2
6	12M	140.35			1400.70		8.98	50	3.309	4	2.6110	28.86	27.25	1.6110	1.5406	1104.1	1129.0
7	12M	165.51	45960	200.00	1652.36	1652.23	10.60	50	3.183	4	3.2350	27.29	25.05	2.2350	2.1385	1105.8	1130.5
8	12M	187.82			1875.90		12.03	50	3.051	4	3.8900	25.64	22.75	2.8900	2.7670	1104.0	1128.3
9	12M	211.50			2112.64		13.55	50	2.897	4	4.6540	23.71	20.06	3.6540	3.4994	1105.7	1129.9
10	12M	233.30	64800	200.00	2330.14	2329.52	14.94	50	2.738	5	4.5440	21.73	17.30	4.4300	4.2433	1107.6	1131.7
<b>Average =</b>																<b>1102.4</b>	<b>1128.4</b>




Figure 6. Flow rate versus flow coefficient.

### 4" Mueller Basket Strainer




Figure 5. Flow rate versus flow coefficient.




Figure 8. Flow rate versus flow coefficient.




Figure 13. Flow rate versus differential pressure.