

ITEM	PART NAME	MATERIAL	ASTM NO.		
1	BODY	CAST IRON	A126 CL. B		
2	SEAT	STAINLESS	T304		
3	PLUG	STAINLESS	T304		
4	SPRING	STAINLESS	T304		
5	BUSHING	STAINLESS	T304		
6	SCREW	STAINLESS	T304		



FOR ADDITIONAL FLOW STRAIGHTENING SEE THE VANE FLEX AT www.metraflex.com/vaneflex



LEAD FREEThe wetted surface of this product contacted by consumable water contains less than one quarter of one percent (0.25%) of lead by weight. Material complies with state codes and standards, where applicable, requiring reduced lead content.

Notes:

Valve is designed for liquid service only. Install 5 to 10 pipe diameters downstream from pump discharge or elbows to avoid flow turbulence. The intake side of CVO 900 series check valves must be mated to a ANSI B16.5 flat faced steel flange. The discharge side can be mated to a ANSI B16.5 flat face steel flange or a wafer style butterfly valve without the use of spools or adapters.

Valve complies with MSS-SP-125-2010.

2-1/2" valve trim is threaded into body.

Qty.	Part Number	Size I.D. (in)	A (in)	B (in)	C (in)	D (in)	E (in)	Cv*	Weight (Lbs)	Bolt Size (in)	Number Of Bolts
	CVOSS9025	2-1/2	7	5-1/2	5-1/2	11/16	1-3/16	110	20	5/8	4
	CVOSS903	3	7-1/2	6	6	15/16	1-3/8	155	26	5/8	4
	CVOSS904	4	9	7-1/4	7-1/4	15/16	1-3/4	278	44	5/8	8
	CVOSS905	5	10	8-1/2	8-1/2	15/16	2	435	56	3/4	8
	CVOSS906	6	11	9-3/4	9-1/2	1	2-1/2	625	79	3/4	8
	CVOSS908	8	13-1/2	12-1/2	11-3/4	1-1/8	3-1/4	1115	137	3/4	8
	CVOSS910	10	16	15-1/2	14-1/4	1-3/16	4-1/4	1770	223	7/8	12

*Cv is the number of U.S. gallons/minute of 60°F water that will flow through a valve with 1 PSI of pressure drop across the valve.

PROJECT INFO	
	I
CUSTOMER:	
PROJECT:	
ENGINEER:	

REV.	1	DRAWING	REVISED	DATE 10/14/2013
M for pipe	es in	ra	lex.	2323 W. HUBBARD ST. CHICAGO, IL 60612 TEL: 312-738-3800 FAX: 312-738-0415 WWW.METRAFLEX.COM
MO	DF	I CV	000	-125-10-55

2.5" - 10" 125# GLOBE STYLE SILENT CHECK VALVE W/ SS TRIM

DRAWN BY: D	KISH	DATE:	8/27/2013
APPROVED: J		DATE:	8/27/2013
SCALE:	DRAWING NILIAR	ED.	

NONE CVO900-125-10-SS